


15008



OAK RIDGE NATIONAL LABORATORY
operated by
UNION CARBIDE CORPORATION
NUCLEAR DIVISION
for the
U.S. ATOMIC ENERGY COMMISSION



HOME
HELP



ORNL - TM - 2489

COPY NO. - 85

DATE - June 2, 1969

Instrumentation and Controls Division

MSBR CONTROL STUDIES

W. H. Sides, Jr.

ABSTRACT

A preliminary study was made of the dynamics and control of a 1000 Mw(e), single-fluid MSBR by an analog computer simulation. An abbreviated, lumped-parameter model was used. The control system included a steam temperature controller and a simplified version of the MSRE reactor temperature control system. The results of the study indicate a need for a variable speed, secondary-salt pump for close control of the steam temperature. During severe transients, considerable care must be taken in designing the control system if freezing or overheating of the salts is to be avoided.

NOTICE This document contains information of a preliminary nature and was prepared primarily for internal use at the Oak Ridge National Laboratory. It is subject to revision or correction and therefore does not represent a final report.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

CONTENTS

	<u>Page</u>
1. Introduction	4
2. Formulation of the Control System	5
2.1 Investigation of Plant Conditions for Less than Full-Load Operation	5
2.2 Transient Behavior of Control Method with Constant Secondary-Salt Flow Rate	6
2.3 Study of Steam Temperature Control with Variable Secondary-Salt Flow Rate	11
3. Results	14
3.1 Decrease in Load Demand	15
3.2 Changes of Reactivity	20
3.3 Step Changes of Reactivity with Controller Disconnected	23
3.4 Ramp Changes of Reactivity with Controller Disconnected	23
3.5 Step Loss of One Secondary-Salt Coolant Loop	26
3.6 Measurement of System Transfer Function	27
4. Concluding Remarks	27

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

1. INTRODUCTION

By means of an analog computer simulation, a preliminary investigation was made of the dynamics and possibilities for control of the proposed 1000-Mw(e) single-fluid Molten-Salt Breeder Reactor (MSBR). For the purposes of this analysis the MSBR plant consisted of a graphite-moderated, circulating-fuel (primary salt) reactor, a shell-and-tube heat exchanger for transferring the generated heat to a coolant (secondary) salt, and a shell-and-tube supercritical steam generator. The analog simulation of the plant consisted of a lumped-parameter heat transfer model for the core, primary heat exchanger, and steam generator; a six-group model of the circulating-fuel nuclear kinetics with temperature reactivity feedbacks; and an external control system. This investigation was concerned with the formulation of this control system and the integrated plant response; it was not concerned with a safety analysis of the system, although some of the transients introduced would be of an abnormal nature (e.g., step changes in the load demand on the plant). It was an initial probe into the response of the system initiated by such perturbations as changes in load demand, reactivity changes, and sudden loss of a secondary-salt coolant loop.

The simulation was carried out on the ORNL Reactor Controls Department analog computer. So that the model would have the maximum dynamic range, the system differential equations were not linearized, and, as a result, the requisite quantity of nonlinear equipment required the model to be severely limited spatially to minimize the number of equations. In addition, the pressure in the water side of the steam generator, as well as in the rest of the plant, and the physical properties of the salts and water were taken to be time invariant. The flow rate of the primary salt and the temperature of the feedwater to the steam generators were also held constant.

In this report, the path taken to arrive at the conceptual control system is outlined along with the equations and values of the system parameters used in the simulation. The results are given as summary curves and graphs of the variations encountered in the system variables (temperatures, flows, etc.).

2. FORMULATION OF THE CONTROL SYSTEM

2.1 Investigation of Plant Conditions for Less than Full-Load Operation

The primary objective of this study was to formulate a control system that would maintain the temperature of the steam delivered to the turbines at a design value of 1000°F during all steady-state conditions and to within a narrow band around this value during plant transients. To accomplish this objective, the first step was to investigate the plant conditions (temperature profile, flows, etc.) for less than full-load operation. (The full-load temperature profile is shown in Fig. 1. The steady-state heat transfer equations and the method used in calculating off-design conditions are given in the Appendix, Sect. 5.1.) Three basic methods of plant operation at less than full load were investigated:

1. The average reactor temperature was held at its 100% power level value, and a secondary-salt bypass line was included in parallel with the steam generators. The salt flow in the bypass line was given by

$$F_4 = F_{20} \left(1 - \frac{P}{P_0} \right), \quad (1)$$

where F_{20} is the secondary-salt flow rate at the 100% power level P_0 .




Fig. 1. Model for Calculating Off-Design Steady-State System Temperature Profiles. Temperature Values are for 100% Power Level.

2. The average reactor temperature was held fixed at its 100% power-level value, and there was no secondary-salt bypass.
3. The secondary-salt flow rate was held fixed at its 100% power-level value, and there was no secondary-salt bypass.

With the first two methods of plant operation the temperature of the secondary salt approached its freezing point of 725°F at power levels $\geq 50\%$ of full power. With the third method, however, the secondary-salt temperatures remained well above the freezing point. With the second method, the ΔT from primary to secondary salt in the primary heat exchanger increased from 150 to 335°F at the primary-salt exit end of the exchanger at 50% power, and the ΔT increased at the steam outlet end of the steam generator as well. The increases in these ΔT 's were reduced for the first method where a valved bypass line had been placed around the steam generator, but this also was more complex because a flow control valve and a variable speed pump were required. The simpler arrangement of the third method showed that the ΔT 's from primary to secondary salt and from secondary salt to steam decreased with decreasing power level except at the feedwater inlet end of the steam generator where it increased only 65°F at 30% power (Fig. 2). This ΔT increase occurred in the coolest part of the system, however. Therefore, the third method of plant control, in which the secondary-salt flow rate was held constant, appeared to be the most promising from the viewpoint of simplicity and thermal stresses on the heat exchangers.

2.2 Transient Behavior of Control Method with Constant Secondary-Salt Flow Rate

A steam-temperature controller was devised to vary the plant temperature profile as shown in Fig. 2. The transient behavior of such a control scheme was investigated by use of the analog computer simulation model shown in Fig. 3. Each heat exchanger was divided into five lumps: two for each of the two fluids and one for the tube walls. The reactor heat transfer system was approximated by two lumps for the circulating primary salt and one for the graphite moderator. A two-group approximation of the circulating-fuel nuclear kinetics equations was used, and temperature reactivity feedbacks were included. (The system equations that describe the model are given in the Appendix, Sect. 5.2. The values of the physical constants and system parameters used as "given" information are shown in Table 1. The values for various system volumes, masses, etc., were calculated from these constants and are listed in Sect. 5.2.)

The steady-state partial-load calculations showed that a reasonable system-temperature profile could be obtained for off-design conditions by maintaining a constant secondary-salt flow rate and by allowing the reactor and secondary-salt temperatures to vary. The transient behavior of such a system was investigated, using at first only that part of the simulation model that included the primary heat exchanger and the steam generator. The secondary-salt flow rate was held constant, and the steam




Fig. 2. Steady-State System Temperature Profiles for 100 and 30% Power Levels.




Fig. 3. Lumped Model of MSBR for Plant Simulation.

Table 1. Physical Constants

Parameter	Primary Salt	Secondary Salt	Steam	Hastelloy N	Graphite
C_p , Btu lb ⁻¹ °F ⁻¹	0.324	0.36	2.17	0.126	0.409
ρ , lb/ft ³	207.8 at 1175°F	117 at 1000°F	19.7, 7.01	548	117
k , Btu hr ⁻¹ °F ⁻¹ ft ⁻¹	—	—	—	11.0	41
Parameter	Primary Heat Exchanger	Steam Generator			
Length, ft	19	63.8			
Triangular tube pitch, in.	0.625	0.875			
Tube OD, in.	0.375	0.5			
Wall thickness, in.	0.035	0.077			
Heat transfer coefficients, Btu hr ⁻¹ ft ⁻² °F ⁻¹ :					
tube side fluid to tube wall	2786	4000			
tube wall conductance	3770	1715			
shell side fluid to tube wall	1624	3745			
<u>Reactor Core</u>					
Octagon:	13 ft across flats.				
Height:	13 ft.				
Fuel:	233U.				
Primary-salt volume fraction:	0.16.				
Graphite to primary-salt heat transfer coefficient:	1700 Btu hr ⁻¹ ft ⁻² °F ⁻¹ .				
Temperature coefficient of reactivity					
primary salt	$-1.333 \times 10^{-5}/\text{°F}$.				
graphite	$1.056 \times 10^{-5}/\text{°F}$.				
Thermal neutron lifetime:	3.6×10^{-4} sec.				
Delayed neutron constants for ²³³ U:					
	i	$\beta_i \times 10^4$	$\lambda_i \text{ sec}^{-1}$		
	1	2.3	0.0126		
	2	7.9	0.0337		
	3	6.7	0.139		
	4	7.3	0.325		
	5	1.3	1.13		
	6	0.9	2.50		

temperature was controlled by altering the temperature of the primary salt entering the primary heat exchanger. The rate of change of this primary-salt temperature was proportional to the steam temperature error, or

$$\frac{dT_2}{dt} = \alpha(T_7 - T_{70}), \quad (2)$$

where α is the controller gain, and T_{70} is the design value of the steam temperature T_7 .

A brief parameter study of α showed that with a gain of about $1^\circ\text{F}/\text{sec}$ change in T_2 per 10°F error in T_7 the steam temperature returned to its design value of 1000°F and remained stable. At higher gains the system became unstable. For a typical transient initiated by a 10% step decrease in load demand from 100 to 90% of full load (Fig. 4), 100 sec was required for the steam temperature to return to within 1°F of its design value. One method of reducing the time required for the steam temperature to return to its design value would be to vary the secondary-salt flow rate during a transient. This would enable close control of the amount of heat delivered to the steam generator, resulting in more restrictive temperature control.

ORNL DWG. 69-6636




Fig. 4. Transient for 10% Step Decrease in Load Demand with Constant Secondary-Salt Flow Model.

2.3 Study of Steam Temperature Control with Variable Secondary-Salt Flow Rate

Restrictive temperature control was accomplished by the control system shown in Fig. 3. The steam-temperature error was allowed to control the rate of change of the secondary-salt flow rate by

$$\frac{dF_2}{dt} = -\alpha(T_7 - T_{70}). \quad (3)$$

Then, after the steam temperature transient, the flow rate was slowly adjusted to its original full-power value by allowing the flow rate error to change the temperature of the primary salt entering the primary heat exchanger by a second controller having a gain of β :

$$\frac{dT_2}{dt} = -\beta\left(1 - \frac{F_2}{F_{20}}\right), \quad (4)$$

where F_{20} is the initial full-power value of the secondary-salt flow rate F_2 .

A brief parameter study of α and β indicated that a reasonable steam-temperature response was obtained when a 1°F steam-temperature error produced a secondary-salt flow rate change of $10\%/min$ and a 1% error in flow rate produced a primary-salt temperature change of $1^\circ\text{F}/min$.

With this control system, a 10% step decrease in power demand from 100 to 90% of full load produced the transient shown in Fig. 5. The steam temperature returned to within 1°F of the design value in about 30 sec, as compared with 100 sec described previously. The maximum change in the secondary-salt flow rate was about 20% , i.e., from 100 to 80% of the design value; the maximum rate of change was about $50\%/min$. The flow rate returned to within 3% of its design value in approximately 250 sec (4.2 min).

With the addition of the reactor heat transfer and nuclear kinetics equations to the model, the temperature of the primary salt entering the primary heat exchanger (reactor outlet temperature) was controlled by inserting or withdrawing control rods to change the reactor power according to the error in the secondary-salt flow rate. Steam temperature control by means of the secondary-salt flow rate remained the same. The rate of change of the set point for the reactor outlet temperature $T_{2\text{ set}}$ was obtained from the error in the secondary-salt flow rate, as follows:

$$\frac{dT_{2\text{ set}}}{dt} = -\beta\left(1 - \frac{F_2}{F_{20}}\right), \quad (5)$$

which is similar to Eq (4). This controller slowly adjusted the reactor outlet temperature set point in the proper direction until the secondary-salt flow rate returned to its 100% power value.

The values for the controller gains α and β were adjusted for the transient runs such that a 3°F error in steam temperature yielded a 10% per min rate of change of the secondary-salt flow rate and a 1% error in the secondary-salt flow rate yielded a 1.7°F per min rate of change of the reactor outlet temperature set point. These values were obtained after a brief parameter study in which a 10% step decrease was initiated in the plant load demand and the gains were adjusted to yield the minimum steam temperature deviation.

The required set point for the reactor power level $P_{r \text{ set}}$ is obtained from the reactor outlet temperature set point by

$$P_{r \text{ set}} = A(T_{2 \text{ set}} - T_1), \quad (6)$$

where A is the proportionality constant between reactor power and reactor ΔT . Thus, as the reactor outlet temperature set point is altered by the secondary-salt flow rate, the reactor power level set point will be altered as well. The error in the reactor power level is given by

$$e = P_r - P_{r \text{ set}}. \quad (7)$$

This error signal is the input to a proportional servo rod controller which is described by the second-order transfer function

$$T(s) = \frac{G\omega^2}{s^2 + 2\zeta\omega s + \omega^2}, \quad (8)$$

where G is the controller gain, ω is the bandwidth, and ζ is the damping factor. In this simulation ω equaled 31.42 radians/sec (5 Hz) and ζ equaled 0.5. These values are typical of the kind and size of servo which may be used in this control-rod-drive service. The gain of the controller was such that for $e \geq 1\%$ of full reactor power the control reactivity addition or withdrawal rate was

$$\frac{d\rho_c}{dt} = 0.1\%/sec. \quad (9)$$

For errors less than 1%, the rate of change of reactivity was proportional to the error. For errors greater than 1%, the reactivity rate was maintained constant at the 0.1%/sec value. Integration of Eq. (9) yields the term ρ_c in the reactivity equation (see Sect. 5.2). This method of controlling the reactor outlet temperature is similar to that used in the MSRE control system.

To obtain more realistic transient results from the simulation, limits were imposed on several of the system variables, as follows:

1. The secondary-salt flow rate was limited to a range from 40 to 110% of the full-power flow rate.
2. The maximum steam flow rate was limited to 110% of the full-power flow rate.
3. The reactor outlet temperature set point was constrained to a range from 1000 to 1400°F (100°F over and 300°F under its full-power value of 1300°F).
4. A 5-sec first-order lag was introduced between the steam flow rate demand F_3 in Eq. (43) in Sect. 5.2 and the steam flow rate in the system F_3 in Eqs. (38) - (40) in order to better simulate the response of a turbine throttle valve.




Fig. 5. Transient for 10% Step Decrease in Load Demand with Variable Secondary-Salt Flow Model.

3. RESULTS

Calculations of the temperature profiles with the system under partial load at steady state were made using the steady-state form of the analog simulation equations in Sect. 5.2. The variation of salt temperatures with various steady-state power levels is shown in Fig. 6. Figure 6 also shows the variation of the same salt temperatures obtained by use of another method of calculation described in Sect. 5.1. Divergence of the two sets of curves begins at about the 50% power level. Thus, if it is assumed that the calculation method of Sect. 5.1 is more reliable for predicting system temperature profiles at steady state, the present analog simulation model is valid only at power levels greater than approximately 50%.

Several transient cases were run which included (1) decreases in load demand P_r from 100% by steps of 10, 30, 50, and 60%; (2) ramp changes of 30 and 70% each at 5 and 10%/min; (3) changes in reactivity of steps of ± 0.05 , ± 0.1 , and -0.5% ; and (4), with the reactivity controller disconnected, (a) reactivity steps of ± 0.05 , $+0.01$, and -0.1% and (b) ramp changes in reactivity of $+0.05$ and -0.1% at 0.1%/min. Also, the step loss of one secondary-salt coolant loop was simulated. The system transfer function $P_r(s)/\rho(s)$ was also measured.




Fig. 6. Variation of Steady-State Salt Temperatures with Power Level.

3.1 Decrease in Load Demand

The action of the system during a typical load demand transient was as follows. When the load demand P_e was decreased, the steam flow rate decreased, transferring less heat out of the steam generators and decreasing the heat transfer coefficient between the steam generator tubes and the steam. This caused the steam temperature to begin to rise. The steam temperature controller sensed the steam temperature error and began to decrease the secondary-salt flow rate at a rate proportional to the temperature error in order to transfer less heat into the steam generator and to decrease the heat transfer coefficient between the secondary salt and the steam-generator tubes. The transfer of heat from the secondary salt at the reduced flow necessary for steam temperature control caused the temperature of the secondary salt leaving the steam generator to decrease. The reduction in flow rate also decreased the amount of heat transferred out of the primary heat exchanger as well as the heat transfer coefficient between the primary-heat-exchanger tubes and the secondary salt. The primary salt was, thus, returned to the reactor at a higher temperature, producing the reactor power error signal ϵ . As this error was sensed by the reactivity servo controller, the control rods were withdrawn (inserting negative reactivity) to reduce the reactor power commensurate with the decrease in load demand. The secondary-salt flow rate controller sensed the decrease in the flow rate and began to decrease the reactor outlet temperature set point at a rate proportional to the secondary-salt flow rate error. A new steady-state operation was achieved when the steam temperature reached its design value of 1000°F and the secondary-salt flow rate its full-power value.

The results of a 30% decrease in load demand from 100% as a step and at rates of 10 and 5%/min are shown in Figs. 7-9. The reduction of the temperature of the secondary-salt leaving the steam generator after a change in load demand is shown in these figures. For large, rapid changes in load demand, the temperature of the secondary-salt may approach its freezing point (725°F). This possibility exists also when the load demand on the plant is increased. Under such conditions the steam temperature initially tends to decrease, causing the steam temperature controller to accelerate the flow of secondary salt, which will transfer more heat into the steam generator. Since this flow may increase only to 110% of full flow, a sufficiently rapid load increase will cause the temperature of the secondary salt leaving the steam generator to decrease and, perhaps, approach the freezing point. However, increases in plant load will usually occur in a more orderly and controlled fashion than decreases since, under accident conditions, decreases will be more probable. Increases in load must be accomplished in a carefully controlled manner.

The data from Figs. 7-9 and the results of other runs made with changes in load demand are summarized in Table 2 which also lists the maximum steam temperature deviations from 1000°F, the maximum required rates of change of the secondary-salt flow rate and of the control reactivity, and the maximum magnitude of the control reactivity required. The highest reactivity rate was well below the 0.1%/sec maximum allowed by the controller.




Fig. 7. Transient for 30% Step Decrease in Load Demand.




Fig. 8. Transient for 30% Ramp Decrease in Load Demand at 10%/min.

ORNL DWG. 69-6641




Fig. 9. Transient for 30% Ramp Decrease in Load Demand at 5%/min.

Table 2. Results of Load Demand Perturbations

A. For Step Losses of Load Demand (from 100%)

	Magnitude of Step (%)		
	10	30	50
Final steady-state temperatures, °F			
T_1	—	1009	976
T_2	—	1183	1098
T_3	—	867	875
T_4	—	1077	1025
Max steam temperature error, °F	13	44	147
Max rate of change of secondary- salt flow rate, %/sec	-0.74	-2.3	-4.3
Max rate of change of reactivity, %/sec	-3.5×10^{-4}	-1.06×10^{-3}	-3.0×10^{-3}
Max value of ρ , %	-0.014	-0.045	-0.075

B. For 30% Ramp Loss of Load Demand from 100 to 70%

	Ramp Rate (%/min)	
	10	5
Max steam temperature error, °F	9	5
Max rate of change of secondary- salt flow rate, %/sec	-0.41	-0.26
Max rate of change of reactivity, %/sec	-1.75×10^{-4}	-1.5×10^{-4}
Max value of control reactivity required, %	-0.045	-0.045

A plot was made of the maximum steam temperature variation from 1000°F as a function of change in load demand (Fig. 10). The plot shows, for example, that a step change of 30% in load demand from 100 to 70% of full power produced a maximum steam temperature deviation of about +42°F at some point in the transient. The break upwards in the three curves for load changes greater than 30% was caused by the 40% lower limit imposed on the secondary-salt flow rate. Changes in load of more than 30% required a change of greater than 60% in the secondary-salt flow rate to maintain control of the steam temperature. When this lower limit was reached, control of the steam temperature was considerably reduced and higher deviations allowed to occur.

3.2 Changes of Reactivity

The results of reactivity steps of ± 0.1 and -0.5% are shown in Figs. 11 and 12. A $+0.1\%$ step yielded a peak reactor power of about 155% as a pulse with a fwhm (full-width, half maximum) of about 0.75 sec. This is an excess energy input of approximately 930 Mw-sec. The reactor outlet temperature peak deviation from 1300°F was about 25°F. The reactor inlet temperature and steam temperatures varied only a few degrees. The control reactivity changed at its maximum allowable speed in a direction to counter the reactivity step. A negative reactivity insertion of -0.5% decreased the reactor power sharply to about 18% before the control reactivity returned it to its 100% level after a 35% overshoot (Fig. 12). The reactor outlet temperature peak change was about -100°F , and the peak steam temperature variation was about -15°F .




Fig. 10. Maximum Steam Temperature Error for Changes in Load Demand from 100%.




Fig. 11. Transient for Steps in Reactivity of $\pm 0.1\%$ with Reactivity Controller Active.

ORNL DWG. 69-6644




Fig. 12. Transient for Step in Reactivity of -0.5% with Reactivity Controller Active.

3.3 Step Changes of Reactivity with Controller Disconnected

With the reactivity controller disconnected so that a reactor power-level error produced no response from the reactivity servo (i.e., no control-rod motion), step changes of +0.05 and -0.1% were studied (Figs. 13 and 14). The +0.05% step change produced a peak reactor power of about 147%, and the reactor temperatures increased to a value commensurate with the negative temperature coefficient of reactivity. The secondary-salt flow rate decreased to its 40% lower limit, after which steam temperature control was lost. The final steam temperature deviation was +75°F. The decrease in secondary-salt flow rate caused a decrease in the temperature of the secondary-salt leaving the steam generator. This temperature decreased to as low as 690°F during the transient, returning to a steady-state value of approximately 735°F. (The secondary-salt freezing point is 725°F.) Similar reactivity transients in runs made without limiting the secondary-salt flow rate to a minimum of 40% of full flow caused this temperature to decrease to well below its freezing point. Without the reactivity controller, control of the reactor outlet temperature set point was lost; the outlet temperature reached 1485°F as its steady-state value (Fig. 12). The steady-state temperature of the secondary-salt leaving the primary heat exchanger was 1470°F.

The negative reactivity step of -0.1% (Fig. 14) required a decrease to 50% in the steady-state reactor power level to produce the compensating reactivity by means of the negative temperature coefficient. The primary-salt temperature at the reactor inlet decreased to approximately 865°F--well below its freezing point of 930°F. The secondary-salt flow rate quickly increased to its 110% limit, after which steam temperature control was lost. The final steam temperature was 840°F. At this low temperature, the steam flow rate increased in an attempt to meet the 100% load demand on the plant, but it was also limited to 110% of full flow rate. These conditions correspond to a plant output of 51% of full power, which matches the observed steady-state reactor power.

3.4 Ramp Changes of Reactivity with Controller Disconnected

With the reactivity controller still disconnected, ramp changes in reactivity of +0.05 and -0.1% at 0.1%/min were inserted. The positive-ramp insertion produced a peak power of about 130%. Again, the secondary-salt flow rate decreased to its 40% lower limit, and steam temperature control was lost. Both of these ramp reactivity perturbations produced much the same response as the step insertions of the same amount except that the reactor power changed more slowly.





Fig. 13. Transient for Step in Reactivity of +0.05% with Reactivity Controller Inactive.




Fig. 14. Transient for Step in Reactivity of -0.1% with Reactivity Controller Inactive.

3.5 Step Loss of One Secondary-Salt Coolant Loop

A simulation of the loss of one secondary-salt coolant loop was attempted as follows (see Fig. 3). In a four-loop system the temperature of the primary-salt entering the reactor core is the average of the temperatures of the primary-salt leaving the four primary heat exchangers. We call the reactor core inlet temperature \hat{T}_1 , and the primary-salt outlet temperatures from the four primary heat exchangers T_{11} , T_{12} , T_{13} , and T_{14} ; then, with perfect mixing

$$\hat{T}_1 = \frac{1}{4}(T_{11} + T_{12} + T_{13} + T_{14}). \quad (10)$$

We now assume that if one of the primary heat exchangers, e.g., number 4, suddenly were to cease to remove heat from the primary salt, the reduction in heat removal would appear as a step increase in the primary-salt outlet temperature T_{14} from 1050 to 1300°F. If the other heat exchangers were to remain unchanged, the reactor core inlet temperature would become

$$\hat{T}_1 = \frac{1}{4}(T_{11} + T_{12} + T_{13} + T_2). \quad (11)$$

Thus, the reactor core inlet temperature would be changed as a step at $t = 0$ from T_1 to \hat{T}_1 .

Similarly, the steam temperature to the turbine is the average of the steam temperatures from the sixteen steam generators, four of which are supplied heat by each secondary-salt coolant loop. If we call the steam temperature at the turbine \hat{T}_7 and the steam generator steam temperatures T_{7i} , then

$$\hat{T}_7 = \frac{1}{16} \sum_{i=1}^{16} T_{7i}. \quad (12)$$

If one secondary-salt loop were to be lost suddenly, four steam generators would be supplied heat no longer, say generators 13, 14, 15, and 16. We assume that this reduction would appear as a step decrease in the steam generator outlet temperatures $T_{7,13}$, $T_{7,14}$, $T_{7,15}$, and $T_{7,16}$ from 1000 to 700°F. The turbine steam temperature would become

$$\hat{T}_7 = \frac{1}{16} \left(\sum_{i=1}^{12} T_{7i} + 4T_6 \right). \quad (13)$$

Thus, the turbine steam temperature would be changed as a step at $t = 0$ from T_7 to \hat{T}_7 .

The results of such a run are shown in Fig. 15. The turbine steam temperature dropped as a step to 925°F, and the reactor inlet temperature rose to 1113°F. This increase in reactor inlet temperature was accompanied by a sudden decrease in the reactor power set point, producing an error signal that indicated high reactor power. The control rods were withdrawn (inserting negative reactivity) and, with the aid of the negative primary-salt reactivity temperature coefficient, the reactor power dropped sharply to 70%. The steam flow rate increased to its 110% limit in an attempt to meet the 100% load demand at the reduced steam temperature. The secondary-salt flow rate increased to its 110% limit in an attempt to maintain the steam temperature at 1000°F. With the loss of 25% of the heat transfer capability in the secondary loop, the reactor temperatures began to rise to meet the 100% load demand. However, when the reactor outlet temperature reached its 1400°F limit, the reactor power had increased to only 92% of full load, and the steam temperature had increased to 956°F. Therefore, under this accident condition and with the temperature and flow limits placed on the system, the plant could not deliver 100% of full load with one secondary-salt loop inoperable. Figure 15 also shows the result of decreasing the load demand to 75% at a rate of 10%/min beginning 325 sec after the step loss of heat transfer capacity. The plant could meet this demand at design steam conditions.

3.6 Measurement of System Transfer Function

The full power system transfer function $P_r(s)/D(s)$ was measured with and without the reactivity servo controller (Fig. 16). The curve for the case with no controller is similar to previous data for the two-fluid MSBR,² although the magnitude of the peak gain at about 3 radians/sec (~0.5 Hz) was greater by a factor of about 6 for the single-fluid case. Adding the servo controller greatly decreased the low-frequency gain, as expected; above the upper cutoff frequency of 5 Hz (~30 radians/sec) for the servo it had no effect.

4. CONCLUDING REMARKS

We have described a preliminary investigation of the control problems associated with the 1000-Mw(e) single-fluid MSBR. The control system was formulated in four basic steps: the first was an estimation of the system temperature profiles for partial load conditions, assuming various possible modes of plant control. Based on these results the most promising mode of plant control was investigated for its dynamic response, using only the primary heat exchanger and steam generator. The results indicated that a variable secondary-salt flow rate would give better steam temperature control during a transient, and this was investigated using the same model. The reactor was then added to the simulation, and the response of the entire plant to various perturbing conditions was studied.




Fig. 15. Transient for Step Loss of One Secondary-Salt Cooling Loop Followed by a 25% Reduction in Load Demand.

The results indicate that careful control will be required to maintain the temperatures of the two salts within the rather narrow allowable limits. Such plant maneuvers as increasing and decreasing the load demand on the plant and certain reactivity excursions might allow these temperatures to decrease below freezing points. However, since the models used in these simulations and calculations were abbreviated, the results are regarded only as indicative of possible trends that might be elucidated in more detailed investigations. Such investigations were not possible with the analog equipment available to the author without either linearizing the simulation equations (reducing the dynamic range) or simulating only a part of the plant at a time, or both. Even then, the modeling of such a unit as a supercritical steam generator would be a difficult task on the analog computer.³ A more detailed simulation than was tried here should be attempted by employing more powerful simulation techniques, e.g., hybrid computation.

ORNL DWG. 69-6648




Fig. 16. System Full-Power Transfer Function $P_r(s)/D(s)$.

5. APPENDIX

5.1 Calculation of Steady-State System Temperature Profiles

The model used in this calculation appears in Figure 1. The two basic equations used were

$$Q = UA \left[\frac{\Delta T_a - \Delta T_b}{\ln \left(\frac{\Delta T_a}{\Delta T_b} \right)} \right] \quad (14)$$

$$Q = FC_p \Delta T \quad (15)$$

where

$$U = \left[\frac{1}{h_i} + \frac{\Delta r}{k} + \frac{1}{h_o} \right]^{-1} \quad (16)$$

and

- Q = heat power (Btu/hr),
- U = overall heat transfer coefficient (Btu hr⁻¹ ft⁻² °F⁻¹),
- A = heat transfer area (ft²),
- T = temperature,
- a, b = ends of heat exchanger,
- F = mass flow rate (lb/hr),
- C_p = specific heat (Btu lb⁻¹ °F⁻¹),
- h_i = heat transfer coefficient inside tubes (Btu hr⁻¹ ft⁻² °F⁻¹),
- k = tube thermal conductivity (Btu hr⁻¹ ft⁻² °F⁻¹/ft),
- Δr = tube wall thickness (ft),
- h_o = heat transfer coefficient outside tubes (Btu hr⁻¹ ft⁻² °F⁻¹).

The heat transfer coefficient inside the tubes h_i was taken to be proportional to the 0.8 power of the flow rate through the tubes; the coefficient on the shell-side of the tubes was taken to be proportional to the 0.6 power of the shell-side flow rate, i.e.,

$$h_i = k_1 F_1^{0.8}, \quad (17)$$

and

$$h_o = k_2 F_0^{0.6}, \quad (18)$$

where k is a proportionality constant.

The following equations were written based on given full-load plant conditions. [The subscript "o" denotes the full-load (100% power) value of all variables.]

In the primary heat exchanger:

$$\frac{Q}{Q_0} = \frac{T_2 - T_1}{T_{20} - T_{10}}, \quad (19)$$

$$\frac{Q}{Q_0} = \frac{U_p [\Delta T]_{lm}}{U_{po} [\Delta T_0]_{lm}}, \quad (20)$$

$$\frac{Q}{Q_0} = \frac{F_4 + F_2}{F_{40} + F_{20}} \frac{T_3 - T_4}{T_{30} - T_{40}}, \quad (21)$$

For the steam generator:

$$\frac{Q}{Q_0} = \frac{F_2}{F_{20}} \frac{T_4 - T_5}{T_{40} - T_{50}}, \quad (22)$$

$$\frac{Q}{Q_0} = \frac{U_s [\Delta T]_{lm}}{U_{s0} [\Delta T_0]_{lm}}, \quad (23)$$

$$\frac{Q}{Q_0} = \frac{F_3}{F_{30}} \frac{T_7 - T_6}{T_{70} - T_{60}}. \quad (24)$$

In Eqs. (20) and (23)

$$\Delta T_{lm} = \frac{\Delta T_a - \Delta T_b}{\ln \left(\frac{\Delta T_a}{\Delta T_b} \right)} \quad (25)$$

The 100% plant-load temperature profile, used as given information in these calculations is shown in Fig. 1. In all calculations that follow, the temperature T_6 of the water entering the steam generator and the steam temperature T_7 were held fixed at their 100% plant load values of 700 and 1000°F, respectively. The values of the tube-side and shell-side heat transfer coefficients for the primary heat exchanger at 100% power were respectively⁵

$$h_{io} = 2786 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$$

and

$$h_{oo} = 1624 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}.$$

For the steam generator the tube-side and shell-side heat transfer coefficients were⁶

$$h_{io} = 4000 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$$

and

$$h_{oo} = 3745 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}.$$

The values of $k/\Delta r$ in Eq. (16) were $3770 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$ for the primary heat exchanger and $1715 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$ for the steam generator.⁵

The overall heat transfer coefficient for the primary heat exchanger was calculated from Eq. (16):

$$U_p = \left[\frac{1}{2786} + \frac{1}{3770} + \frac{1}{1624} \left(\frac{F_{40} + F_{20}}{F_4 + F_2} \right)^{0.6} \right]^{-1}. \quad (26)$$

The overall heat transfer coefficient for the steam generator was

$$U_s = \left[\frac{1}{3745} \left(\frac{F_{20}}{F_2} \right)^{0.6} + \frac{1}{1715} + \frac{1}{4000} \left(\frac{F_{30}}{F_3} \right)^{0.8} \right]^{-1}. \quad (27)$$

Equations (19) through (23) form a set of five equations in eight unknowns. The unknowns are Q/Q_0 , $(F_1 + F_2)/(F_{40} + F_{20})$, F_2/F_{20} , and T_1 , T_2 , T_3 , T_4 , and T_5 . Several variables must be specified in order to solve the set of equations. The variable Q/Q_0 , the relative power level, was used as a parameter. The remaining two variables were specified in three ways, forming the three case studies reported here.

Case 1: Average reactor temperature fixed at its 100% power level value and the bypass flow given by

$$F_4 = F_{20} \left(1 - \frac{Q}{Q_0} \right).$$

Case 2: Average reactor temperature fixed at its 100% power level value and no bypass line around the steam generator, i.e.,

$$\frac{T_1 + T_2}{2} = \frac{T_{10} + T_{20}}{2}$$

and

$$F_4 = 0.$$

Case 3: Constant flow rate of the secondary-salt and no bypass line, i.e.,

$$F_4 = 0$$

and

$$\frac{F_2}{F_{20}} = 1.$$

5.2 Description of the Analog Simulator Model

The following equations describe the analog simulation model used in this study and shown in Fig. 3. The heat transfer driving force across the heat exchanger tubes and from the graphite to the primary salt is shown by the dotted lines in the figure. The mass of the primary salt and the primary-salt-to-tube-wall heat transfer area in the primary heat exchanger were equally divided between the two primary-salt lumps. Similar statements can be made about each of the remaining pairs of lumps except in the case of the two steam lumps.

For the two steam lumps w_1 and w_2 , the density of the steam varies by a factor of 7 in passing through the steam generator.⁶ The mass of the steam in lump 1 was determined by the average density of the steam in the half of the steam generator at the steam exit end. The mass was determined in a similar manner for lump 2. The steam pressure was assumed constant at all times.

For the reactor core (see Fig. 3):

$$M_G C_{pG} \frac{dT_G}{dt} = h_{fG} A_{fG} (T_r - T_G) + k_G P_r, \quad (28)$$

$$M_{fr} C_{pf} \frac{dT_r}{dt} = F_1 C_{pf} (T_1 - T_r) + k_r P_r + 0.5 h_{fG} A_{fG} (T_G - T_r), \quad (29)$$

$$M_{f2} C_{pf} \frac{dT_2}{dt} = F_1 C_{pf} (T_r - T_2) + k_2 P_r + 0.5 h_{fG} A_{fG} (T_G - T_r). \quad (30)$$

For the primary heat exchanger:

$$M_f C_{pf} \frac{dT_f}{dt} = F_1 C_{pf} (T_2 - T_f) - h_f A_p (T_f - T_{t1}), \quad (31)$$

$$M_f C_{pf} \frac{dT_1}{dt} = F_1 C_{pf} (T_f - T_1) - h_f A_p (T_f - T_{t1}), \quad (32)$$

$$M_{t1} C_{pt} \frac{dT_{t1}}{dt} = 2h_f A_p (T_f - T_{t1}) - 2h_{sp} A_p (T_{t1} - T_{s1}), \quad (33)$$

$$M_{sp} C_{ps} \frac{dT_4}{dt} = F_2 C_{ps} (T_{s1} - T_4) - h_{sp} A_p (T_{s1} - T_{t1}), \quad (34)$$

$$M_{sp} C_{ps} \frac{dT_{s1}}{dt} = F_2 C_{ps} (T_3 - T_{s1}) - h_{sp} A_p (T_{s1} - T_{t1}). \quad (35)$$

For the steam generator:

$$M_{ss} C_{ps} \frac{dT_{s3}}{dt} = F_2 C_{ps} (T_5 - T_{s3}) - h_{ss} A_s (T_{s3} - T_{t2}), \quad (36)$$

$$M_{ss} C_{ps} \frac{dT_8}{dt} = F_2 C_{ps} (T_{s3} - T_8) - h_{ss} A_s (T_{s3} - T_{t2}), \quad (37)$$

$$M_{t2} C_{pt} \frac{dT_{t2}}{dt} = 2h_{ss} A_s (T_{s3} - T_{t2}) - 2h_w A_s (T_{t2} - T_w), \quad (38)$$

$$M_{w1} C_{pst} \frac{dT_7}{dt} = F_3 C_{pst} (T_w - T_7) - h_w A_s (T_w - T_{t2}), \quad (39)$$

$$M_{w2} C_{pst} \frac{dT_w}{dt} = F_3 C_{pst} (T_6 - T_w) - h_w A_s (T_w - T_{t2}), \quad (40)$$

$$T_4(t) = T_5(t + \tau_1), \quad (41)$$

$$T_8(t) = T_3(t + \tau_2), \quad (42)$$

$$P_E = F_3 C_{pst} (T_7 - T_6), \quad (43)$$

As in the steady-state off-design calculations in Sect. 5.1

$$\frac{h_{sp}}{h_{spo}} = \left(\frac{F_2}{F_{20}} \right)^{0.6},$$

$$\frac{h_{ss}}{h_{sso}} = \left(\frac{F_2}{F_{20}} \right)^{0.6},$$

$$\frac{h_w}{h_{wo}} = \left(\frac{F_3}{F_{30}} \right)^{0.8},$$

where

- T = temperature of lump,
 P_r = reactor power,
 P_E = load demand (power to turbines),
 M_f = mass of primary-salt lump,
 M_G = mass of graphite in core,
 M_t = mass of tube-wall lump,
 M_s = mass of secondary-salt lump,
 M_w = mass of steam (water) lump,
 C_p = specific heat of lump,
 k_G = fraction of power generated in graphite,
 $k_{r,2}$ = fraction of power generated in primary-salt lumps,
 A = heat transfer area of lump,
 F = salt or steam flow rate,
 h_f = primary-salt-to-tube heat transfer coefficient,
 h_{fG} = graphite-to-primary-salt heat transfer coefficient,
 h_{sp} = tube-to-secondary-salt heat transfer coefficient in primary heat exchanger,
 h_{ss} = secondary-salt-to-tube heat transfer coefficient in steam generator,
 h_w = tube-to-steam heat transfer coefficient,
 τ = transit time of secondary salt between the primary heat exchanger and the steam generator (assumed to be 10 sec).

The reactor kinetics equations used in the simulation were⁷

$$\frac{dP_r}{dt} = \frac{\rho - \beta}{\Lambda} P_r + \sum_i \lambda_i C_i, \quad (44)$$

$$\frac{dC_i}{dt} = \frac{\beta_i}{\Lambda} P_r - \lambda_i C_i - \frac{1}{\tau_c} C_i + \frac{e^{-\lambda_i \tau_L}}{\tau_c} C_i(t - \tau_L), \quad (45)$$

also

$$\rho = \rho_0 + \alpha_f \Delta T_f + \alpha_G \Delta T_G + \rho_c, \quad (46)$$

where

- β = delayed neutron fraction,
- l = neutron generation time,
- λ_i = i th delayed group decay constant,
- τ_c = transit time of primary salt through the core,
- τ_L = transit time of primary salt through external loop,
- ρ_0 = positive, net steady-state reactivity associated with the circulating fuel,
- α_f = temperature coefficient of reactivity for the primary salt,
- α_G = temperature coefficient of reactivity for the graphite,
- ρ_c = control rod reactivity.

The simulation of $C_i(t - \tau_L)$ requires a transport lag device of which only two were available in the Reactor Controls Department analog computer. Both were employed in the simulation of Eqs. (41) and (42), the transport lag between heat exchangers. Therefore, the term $C_i(t - \tau_L)$ was approximated by

$$C_i(t - \tau_L) \approx C_i(t) - \tau_L \frac{dC_i(t)}{dt}, \quad (47)$$

With this approximation Eq. (45) became

$$\frac{dC_i}{dt} = \frac{\beta_i}{lb_i} P_r - \frac{\lambda_i}{a_i b_i} C_i, \quad (48)$$

where

$$a_i = \frac{\lambda_i \tau_c}{\lambda_i \tau_c + 1 - \exp(-\lambda_i \tau_c)},$$

and

$$b_i = 1 + \frac{\tau_L}{\tau_c} \exp(-\lambda_i \tau_L).$$

The coefficients for these equations were calculated using the physical constants listed in Table 1. The resulting calculated values for the various system volumes, masses, etc., were as follows:

1. For the reactor core (active region only)
 - Initial heat flux, 7.68×10^9 Btu/hr [2250 Mw (th)]
 - Primary-salt flow rate, 9.48×10^7 lb/hr
 - Active core volume, 1820 ft^3 (primary salt plus graphite)
 - Primary-salt volume, 291 ft^3
 - Graphite volume, 1529 ft^3
 - Primary-salt mass, 60,512 lb
 - Graphite mass, 178,873 lb
 - Number of graphite elements, 1223
 - Heat transfer area, $22,121 \text{ ft}^2$
 - Primary-salt velocity, 5.66 ft/sec
 - Core transit time of primary salt, 2.30 sec
 - External loop transit time of primary salt, 6.5 sec
 - Steady-state reactivity ρ_0 , 0.00161.

2. For the primary heat exchanger (total for four exchangers, tube region only)
 - Secondary-salt flow rate, 7.11×10^7 lb/hr
 - Overall heat transfer coefficient, $806 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$
 - Primary-salt heat transfer area, $55,000 \text{ ft}^2$
 - Number of tubes, 29,400
 - Tube metal volume, 145 ft^3
 - Primary-salt volume, 283 ft^3
 - Secondary-salt volume, 883 ft^3
 - Volume of four primary heat exchangers, 1311 ft^3
 - Primary-salt mass, 58,800 lb
 - Tube mass, 79,400 lb
 - Secondary-salt mass, 103,300 lb
 - Transit time of primary salt, 2.23 sec
 - Transit time of secondary salt, 5.23 sec
 - Primary-salt velocity, 8.5 ft/sec
 - Secondary-salt velocity, 3.6 ft/sec.

3. For the steam generator (total for 16 steam generators, tube region only)
 - Steam flow rate, 1.18×10^7 lb/hr
 - Overall heat transfer coefficient, $909 \text{ Btu hr}^{-1} \text{ ft}^{-2} \text{ }^\circ\text{F}^{-1}$
 - Heat transfer area, $56,300 \text{ ft}^2$
 - Number of tubes, 6740
 - Tube metal volume, 306 ft^3
 - Secondary-salt volume, 1394 ft^3
 - Steam volume, 281 ft^3
 - Volume of 16 steam generators, 1980 ft^3

Secondary-salt mass, 163,000 lb
Tube mass, 168,000 lb
Steam mass, 3750 lb
Secondary-salt transit time, 8.26 sec
Steam transit time, 1.15 sec
Secondary-salt velocity, 7.72 ft/sec
Average steam velocity in lump w_1 , 212 ft/sec
Average steam velocity in lump w_2 , 76 ft/sec

The simulation equations coefficients were calculated from these values.

REFERENCES

- ¹ J. R. Tallackson, MSRE Design and Operations Report, Part IIA: Nuclear and Process Instrumentation, ORNL-TM-729 (February 1968).
- ² Private communication from T. W. Kerlin, ORNL.
- ³ F. H. Clark and O. W. Burke, Dynamic Analysis of a Salt Supercritical Water Heat Exchanger and Throttle Used with MSBR, ORNL-TM-2405 (January 1969).
- ⁴ C. O. Bennett and J. E. Myers, Momentum, Heat, and Mass Transfer, pp. 333-50, McGraw-Hill, New York, 1962.
- ⁵ Private communication from C. E. Bettis, ORNL.
- ⁶ General Engineering Division Design Analysis Section, Design Study of a Heat-Exchange System for One MSBR Concept, ORNL-TM-1545 (September 1967).
- ⁷ J. MacPhee, "The Kinetics of Circulating Fuel Reactors," Nucl. Sci. Eng. 4, 588-97 (1958).



ACKNOWLEDGMENTS

The author acknowledges the suggestions of S. J. Ditto and J. L. Anderson for the control system design and for improvement of the system and the model.



INTERNAL DISTRIBUTION

- | | |
|---------------------------------|--|
| 1. J. L. Anderson | 30. M. I. Lundin |
| 2. C. F. Baes | 31. R. E. MacPherson |
| 3. S. J. Ball | 32. H. A. McLain |
| 4. H. F. Bauman | 33. H. E. McCoy |
| 5. S. E. Beall | 34. J. R. McWherter |
| 6. M. Bender | 35. R. L. Moore |
| 7. E. S. Bettis | 36. E. L. Nicholson |
| 9. E. G. Bohlmann | 37-61. L. C. Oakes |
| 10. C. J. Borkowski | 62. R. W. Peele |
| 11. R. B. Briggs | 63. A. M. Perry |
| 12. F. H. Clark | 64-65. M. M. Rosenthal |
| 13. C. W. Collins | 66. Dunlap Scott |
| 14. F. L. Culler | 67-68. W. H. Sides |
| 15. S. J. Ditto | 69. O. L. Smith |
| 16. W. P. Eatherly | 70. J. R. Tallackson |
| 17. J. R. Engel | 71. R. E. Thoma |
| 18. D. E. Ferguson | 72. J. R. Weir |
| 19. L. M. Ferris | 73. M. E. Whatley |
| 20. W. K. Furlong | 74. J. C. White - A. S. Meyer |
| 21. W. R. Grimes - G. M. Watson | 75. L. V. Wilson |
| 22. A. G. Grindell | 76. Gayle Young |
| 23. R. H. Guymon | 77-78. Central Research Library |
| 24. P. M. Haubenreich | 79. Document Reference Section |
| 25. R. E. Helms | 80-82. Laboratory Records Department |
| 26. P. P. Holz | 83. Laboratory Records, ORNL R. C. |
| 27. P. R. Kasten | 84. ORNL Patent Office |
| 28. T. W. Kerlin | 85-99. Division of Technical Information Extension |
| 29. R. B. Korsmeyer | 100. Laboratory and University Division, ORO |

EXTERNAL DISTRIBUTION

101. C. B. Deering, AEC, Washington, D. C.
102. A. Giambusso, AEC, Washington, D. C.
103. George McCright, Black and Veatch Engineers,
1500 Meadowlake Parkway, Kansas City, Mo. 64114